



Refrigeration and Air
Conditioning Controls

SETTINGS

**AKA 243/
AKA 244**



084R9717



RI8AM353

AKA 243/244 indstillinger AKA 243/244 Einstellungen Réglages AKA 243/244 Ajustes AKA 243/244	Software version 5.3x Software Version 5.3x Logiciel version 5.3x Versión de software 5.3x	Systemadresse System address Adresse système Sistema dirección Network : Address = _____:_____
---	---	--

Indstillet af: *Firma / Person / Dato*
 Set by: *Firm / Person / Date*
 Eingestellt von: *Firma / Person / Datum*
 Réglé par: *Firm / Personne / Date*
 Ajustado por: *Compañía / Persona / Fecha*

-----/-----/-----

Funktion: Gatewayen sender information - fra følgende AKC regulatorer.....
 - til

Der er tilsluttet printer (ja/nej): _____ BUS terminering er åben (ja/nej): _____

Function: The gateway sends information - from the following AKC controller

Printer connection (yes/no): _____ BUS termination is open (yes/no): _____

Funktion: Gateway sendet Information - von folgenden AKC Reglern

Drucker ist angeschlossen (ja/nein): _____ BUS Drahtverbindungen sind offen (ja/nein): _____

Fonction: envoie ses informations - en provenance des AKC suivants

Imprimante installée (oui/non): _____ Bouclage BUS ouvert (oui/non): _____

Función: El interface (gateway) envia información - desde los siguientes controles AKC

Impresore instalada (Si/No): _____ Terminación BUS abierto (Si/No:) _____

Time setting

Year	Month	Date	Hour	Minute	Summer time
------	-------	------	------	--------	-------------

Manual	Auto
OFF	OFF
ON	ON

Start	Stop
Month:	Month:
Date:	Date:
Hour:	Hour:

Configuration

Code No.084B2260/084B2265/084B2266	Normal limit	Extended limit	Extended code	Service code
Prog.ver 5.xx	x=	[1]	[40]	[99]

Dansett time	Dansett logoff	Password "on/off"
[60]	[2]	Delete password

Address & GWtype

Network address		Change GWtype	Boot gateway
↓		↓	-
Network:	Address:	PC Modem MSS	
		0 2 : ___	

Communication setup - Router

Edit line



Lower limit Network	Upper limit Network	Port No. 1= DANBUSS 2= PC-/Modem/MSS	Address / Phone No./IP Address 0-123, 125 / Phone No. Default = 0

Communication setup - RS 232 Port /

PC

RS 232 Port speed Baud rate (9600)	Boot gateway
	Boot gateway

- RS 232 Port

Modem and MSS

Life time sec.	RS 232 port speed Baud rate 9600	Boot gateway
		-

(Address = 1 - 123, 125 for AKA 244)

(Address = 61 - 123, 125 for AKA 243)